

AFC Telford – Regulated Stands Certificates

Certificate		Last Received	Next Due Date	28 days of due date	28 days for any remedial works to be done	Comments
Escape lighting battery test	6 month	20/12/17	20/6/18	20/7/18	20/8/18	Completed
Escape lighting generator	12 month	28/2/18	28/2/19	28/3/19	28/4/19	Completed
Structural Safety Assessment	12 month	22/3/17	22/3/18	22/4/18	22/5/18	The Ground Safety Structural Report commissioned by undertaken on 22 nd March 2017 contains 11 recommendations of work to the value of £50,500 to be invested in repairs between now and 2020. AFC Telford confirm that all works are being programmed in over the next year.
Load Testing	12 month	10/4/17	10/4/18	10/5/18	10/6/18	The Test Report for Barrier Testing Report No. R17380-2 carried out on 10 th April 2017 confirms that the barrier W10 outside the sponsor's box that has been changed to a box section and has passed the load test.
Fire Alarm:						
West Stand	12 month	6/3/18	6/3/19	6/4/19	6/5/19	Work to the fire detection system has been completed and tested on 6 th March 2018. AFC Telford are awaiting receipt of certificates
East Stand	12 month	6/3/18	6/3/19	6/4/19	6/5/19	Work to the fire detection system has been completed and tested on 6 th March 2018. AFC Telford are awaiting receipt of certificates

AFC Telford – Regulated Stands Certificates

North Stand	12 month	6/3/18	6/3/19	6/4/19	6/5/19	Work to the fire detection system has been completed and tested on 6 th March 2018. AFC Telford are awaiting receipt of certificates
South Stand	12 month	6/3/18	6/3/19	6/4/19	6/5/19	Work to the fire detection system has been completed and tested on 6 th March 2018. AFC Telford are awaiting receipt of certificates
Public Address system	12 month	6/3/18	6/3/19	6/4/19	6/5/19	Some works were linked to the fire detection system. Work to the fire detection system has been completed and tested on 6 th March 2018. AFC Telford are awaiting receipt of certificates
Fire fighting equipment	12 month	July 17	July 18	Aug 18	Sept 18	Next due July 18
Fire Risk Assessment	12 month	March 18	March 19	April 19	May 19	Undertaken 6 th March, report to follow.
Electrical installation	3 year	20/10/14	20/10/17	20/11/17	20/12/17	Applies to new installations. AFC Telford are arranging for this testing as soon as possible.
CCTV	12 month	See notes	See notes	See notes	See notes	AFC Telford advises that, 'The company that we had out to service it, will not service it, as they say the system is obsolete and needs replacing. This will cost several £000s, which we simply do not have, this requires huge investment.' The SAG agreed that, as the system is currently operational, an investigation should be made to the circumstances around which CCTV is required as part of the certification, and alternative means of providing either CCTV coverage or a different means of observing and recording crowd activity is investigated. This is

AFC Telford – Regulated Stands Certificates

						will be monitored at the next match day inspection. CCTV is not required as part of the club's licence to sell alcohol. Stewards are used in those few areas not covered by CCTV. AFC Telford state CCTV is not a requirement of the FA.
Lightening conductor	12 month	22/2/18	22/2/19	22/3/19	22/4/19	Tested February 2018

Correct as at: 5 March 2018